

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

**0809 - CPR - 1110**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

### **Thermal insulation products for building equipment and industrial installations**

presented on page 2

produced by

**Steinull hf.**  
Skarðseyri 5  
550 Sauðárkrókur, Iceland

and produced in the manufacturing plant

**Steinull hf.**  
Skarðseyri 5  
550 Sauðárkrókur, Iceland

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

**EN 14303:2009 + A1:2013**

under system 1 set out in this certificate are applied and that

**the construction products fulfil all the prescribed requirements for these performances.**

This certificate was first issued on January 22, 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performances of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.

Espoo January 22, 2015



Tiina Tirkkonen  
Product Manager



Ritva Paalanen  
Lead Assessor

Product name		Reaction to fire	Thermal conductivity, W/mK	Designation code
Iceland	English			
Stokkæinangrun T	ICEROCK R80 Alu Paroc Hvac Fire Mat AluCoat	A1	0,034	MW-EN14303-T2-MW1
Stokkæinangrun L	ICEROCK DUCTWRAP Icerock Ductwrap	A1	0,034	MW-EN14303-T2-MW1
Plötur 40 m/áli	ICEROCK DUCTSLAB	A1	0,034	MW-EN14303-T2-MW1
Beygjuull		A1	0,034	MW-EN14303-T2-MW1